

Anael Dominguez (Planning)

From: Emily McGahee (Environmental Health)
Sent: Thursday, March 9, 2023 12:21 PM
To: Anael Dominguez (Planning); Randi Doveton (Planning)
Cc: Chad Harper (Environmental Health); Harper, Chad
Subject: Tentative HCPC Agenda 4.3.23

Please find Environmental Health comments below:

Item 1, 5303 Browns Bridge Road, Sadegh: Must meet all Environmental Health commercial septic system permitting requirements. A detailed business plan must be submitted to Hall County Environmental Health for review. Current septic system permitted under OSC930 is designed for 5 employees, not public restrooms.

Item 2, 1563 Calvary Church Road, Southern Utility Group: Must meet all Environmental Health commercial septic system permitting requirements. A detailed business plan must be submitted to Hall County Environmental Health for review.

Item 3, Unnamed Road: No comment.

Item 4, PRD Amendment: No comment.

Emily McGahee
Hall County Environmental Health
Hall County Government Center
2875 Browns Bridge Road
Mailing: PO Box 5901
Gainesville, GA 30504
(770) 531-3973
(770) 531-6767 (fax)

<http://dph.georgia.gov/environmental-health> (State Website)
<http://www.phdistrict2.org/HallCounty.htm> (District Website)
<http://www.hallcounty.org/devserv/environmental.asp> (County Website & Forms)