

Anael Dominguez (CDI: Planning)

From: John Hornick (Fire Services)
Sent: Thursday, June 22, 2023 4:02 PM
To: Anael Dominguez (CDI: Planning)
Cc: Randi Doveton (CDI: Planning)
Subject: Fire Comments

Monday, July 24, 2023 Hall County Planning Commission Meeting.

1. [2196 Centennial Drive | Use Subject to County Commission Approval | on a 4.19± acre parcel located on the north side of Centennial Drive approximately 1,235 feet from its intersection with Centennial Circle | Zoned I-I; Tax Parcel 08013 003033 | Proposed Use: food processing plant involving the further processing of animal or animal product | ** Commission District 4 | Brian Jones, applicant.](#)

Hall County Fire Marshal's Comments

- 1) [If approved a engineered site development plan will need to be submitted to Hall County for review and approval by the Development Review Committee](#)
- 2) [Based off the size of the proposed building a supervised fire protection system will be required](#)
- 3) [Underground fire line will be required for the fire protection water supply](#)
- 4) [Gainesville Fire Service Vault will be required](#)
- 5) [Additional fire hydrant\(s\) may be required](#)
- 6) [Fire apparatus accessibility must meet International Fire Code Standards.](#)
- 7) [Emergency responder radio coverage test will be required](#)

Regards,

John Hornick, NPQ Fire Service Plans Examiner 1
Lieutenant, Hall County Fire Rescue
Hall County Government
Main: 770-531-6838 | Cell: 404-597-0083
Website: www.Hallcounty.org

