

Anael Dominguez (CDI: Planning)

From: Emily McGahee (Environmental Health)
Sent: Friday, August 18, 2023 12:02 PM
To: Anael Dominguez (CDI: Planning); Randi Doveton (CDI: Planning); Beth Garmon (CDI: Planning)
Cc: Kelly Hairston (Environmental Health); Chad Harper (Environmental Health)
Subject: HCPC Tentative Agenda 9.18.23

Item 1, 3922 Green Drive, Poole: All proposed lots must meet Hall County Board of Health Lot Size Resolution requirements. This plat is currently under review by the Hall County Plat Review Team and Environmental Health can approve the subdivision plat of Lot 5 into 3 parcels as currently proposed. Any reconfigurations of currently submitted plat due to other county department requirements will require further review; additional requirements/fees may apply and approval of changes/reconfigurations is not implied.

Item 2, 3268 Whidby Road, Bazemore: Please note that Zoning approval does not imply approval from other county departments. All proposed structures must meet required setbacks to the existing septic system. An existing system evaluation will be required to verify setbacks and area available for full future repair of septic system. Due to age of existing septic system, it cannot be modified, only replaced. Replacement of existing septic system will require Level 3 soil evaluation and area available to relocate system and have full, feasible future repair of septic system. Application for an existing system evaluation and/or completion of additional requirements for Environmental Health does not guarantee approval.

Item 3, 5991 Circle Four Ranch, Loyd: Must meet all Environmental Health residential septic system permitting requirements.

Item 4, 7042 Baker Lane, Labovitz: Must meet all Environmental Health commercial septic system permitting requirements. A detailed business plan must be submitted to Hall County Environmental Health for review. Septic Permit OSC-7948 was issued on February 24, 2023 to accommodate a 36' x 60' barn with bathroom.

Item 5, 8545 Belton Bridge Road, Mallard View: No comment.

Items 6A-D, 3405/3419/3505 Cleveland Hwy/3906 Donna Drive, Dutton Properties: Must meet all Environmental Health commercial septic system permitting requirements. A detailed business plan must be submitted to Hall County Environmental Health for review. Additional items, including, but not limited to: recorded plat, soil evaluation, and septic system installation/modification may be required after review of business plan.

Item 7, 3302/3212 Antioch Campground Church/3446/3450/3456 Looper Lake Road: No comment. Public sewer.

Items 8A&B, 4053 Cleveland Hwy, Hunt: Non-domestic wastewater treatment and disposal must be permitted by EPD.

Items 9A-C, 1731 Friendship Road, Wilbanks: No comment. Public Sewer.

Emily McGahee
Hall County Environmental Health
Hall County Government Center
2875 Browns Bridge Road
Mailing: PO Box 5901
Gainesville, GA 30504
(770) 531-3973
(770) 531-6767 (fax)

<http://dph.georgia.gov/environmental-health> (State Website)

<http://www.phdistrict2.org/HallCounty.htm> (District Website)

<https://www.hallcounty.org/192/Environmental-Health> (County Website & Forms)