



# Hall County Government

FINANCIAL SERVICES

**Notice – Addendum 2**  
**Project Name: Laurel Park Baseball Field Fencing**  
**IFB#: 030-44**

**December 6, 2023**

POST OFFICE DRAWER 1435  
GAINESVILLE, GA 30503

t: 770.535.8270 | f: 770.531.6711

DIRECTOR  
**Wesley Geddings**

The following questions were submitted by various vendors after the 1<sup>st</sup> Addendum was issued.

Q: What about the netting over the walkways?

A: The netting over the walkways will not be part of this project. It will be bid out separately at a later date.

Q: Can you inform me on the back fence height or gate height?

A: Fields 1 and 2 – The backstops are 28' high, those step down to 10' high fences for roughly 65', then to a 6' fence for the remainder of the foul and outfield fence.

Fields 3 and 4 - The backstops are 28' high, those step down to 10' high fences for roughly 65', then to a 6' fence for the remainder of the foul and outfield fence.

Q: How tall are the back stops on all four (4) fields?

A: Fields 1 and 2 - 28'

Fields 3 and 4 – 20'

Q: Do you have a recommendation on the line post and gate post demotions?

A: Line posts should stand roughly 6' tall. Entry gate dimensions should be to be 4' wide and at least 7' tall (2 total per field), double gates would need to be 10' wide (2 per field), outfield gate would be 4' wide by 6' high.

Q: Will the dugouts be in Chain-link or Block?

A: The dugouts would be chain-link.

Q: What are the dimensions of each backstop per field (i.e., length, width & height)?

A: Fields 1 and 2 – Backstops are 28' high – 20' wide along the back with another 10' wide section that starts down the foul line. It then steps down to a 10' high section that is roughly 65' long, then to a 6' high section that extends to the foul pole and around the outfield fence.

Fields 3 and 4 - Backstops are 20' high – 20' wide along the back with another 10' wide section that starts down the foul line. It then steps down to a 10' high section that is roughly 65' long, then to a 6' high section that extends to the foul pole and around the outfield fence.

Q: What is the fence/gate heights per field?

A: The fence heights are listed above. Entry gate dimensions should be to be 4' wide and at least 7' tall (2 total per field), double gates would need to be 10' wide (2 per field), outfield gate would be 4' wide by 6' high.

Q: What size line posts, top rail & terminal post per field?

A: Line Post – 2 1/2"  
Top Rail – 1 5/8"  
Terminal Post – 3"

Q: How many gates per field and what size gate posts?

A: 5 gates total (see below for more detail). Terminal posts – 3", Top Rail – 1 5/8", Line Post – 2 1/2".

Q: Will the hardware for the gates be commercial or residential?

A: Commercial.

Q: How many and what kind of gates and how wide (Double Drive, Single Panel) per field?

A: Entry gate dimensions should be to be 4' wide and at least 7' tall (2 total per field), double gates would need to be 10' wide (2 per field), outfield gate would be 4' wide by 6' high.

Q: For clarification, all fencing for each field will be 6ga (core) black vinyl chain link?

A: Fencing should be 6ga total with vinyl (9ga core).

Q: Will any of the fencing have Mid-rail or Bottom Rail?

A: The backstop would need a bottom rail and mid-rail supports for the lower 10' section. The adjacent.

All other Terms and Conditions remain the same.

Hall County Board of Commissioners  
Mike Hawkins, Buyer