

Kaitlyn Elliott (Planning)

From: Emily McGahee (Environmental Health)
Sent: Thursday, September 5, 2024 4:55 PM
To: Kaitlyn Elliott (Planning); Beth Garmon (CDI: Planning); Katie L. Greenway (CDI: Planning)
Cc: Kelly Hairston (Environmental Health); Chad Harper (Environmental Health)
Subject: HCPC Tentative Agenda 10.7.2024

Follow Up Flag: Follow up
Flag Status: Completed

Please find Environmental Health comments below:

Items 1A,B,C, 6111 Oak Hill Drive, Hoffmann: All proposed structures must meet all residential permitting requirements and/or required setbacks to existing septic system. An existing system evaluation/site visit will be required for Environmental Health to process the building permit application.

Item 2, 3654 Thompson Bridge Road, Benson: No comment. Public sewer.

Item 3, 1600C Athens Hwy, Vargas: No floor drains or process wastewater to be discharged to the existing septic system. Domestic waste only.

Item 4, 6147 Dahlonega Hwy, Rich: Must meet all Environmental Health commercial septic system permitting requirements. Further determination will be made during the civil plan review process. A detailed business plan must be submitted to Hall County Environmental Health for review. Additional items, including, but not limited to: recorded plat, soil evaluation, and septic system installation/modification may be required after review of business plan.

Item 5, 4137 Short Rd, Allen: All proposed lots must meet Hall County Board of Health Lot Size Resolution requirements. This plat is currently under review by the Hall County Plat Review Team, which is waiting for revisions to be submitted for review under case number HPLT24-0090.

Item 6, 6000 Wellspring Trail, Barnes: Must meet all Environmental Health commercial septic system permitting requirements. Further determination will be made during the civil plan review process. A detailed business plan must be submitted to Hall County Environmental Health for review. Additional items, including, but not limited to: recorded plat, soil evaluation, and septic system installation/modification may be required after review of business plan. A Food Service permit/plan review may be required after review of business plan

Item 7, 5552 Bogus Road, Barnes: All proposed lots must meet Hall County Board of Health Lot Size Resolution requirements. Please note that Zoning approval does not imply approval from other county departments. Further determination will be made during the plat review process.

Item 8, 7011/7051 Pony Lake Road, Roys: Septic Permit OSC-9259 was issued on May 30, 2024 for the proposed structure.

Item 9, 7051 Pony Lake Road, Roys: Septic Permit OSC-9259 was issued on May 30, 2024 for the proposed structure.

Item 10, 2002 Memorial Park, Sancen: Must meet all Environmental Health commercial septic system permitting requirements. A detailed business plan must be submitted to Hall County Environmental Health for review. Additional items, including, but not limited to: recorded plat, soil evaluation, and septic system installation/modification may be required after review of business plan. An onsite sewage management system (and bathroom structure) will be required on the property if it is to be occupied for two hours or more.

Emily McGahee

Hall County Environmental Health

Hall County Government Center

2875 Browns Bridge Road

Mailing: PO Box 5901

Gainesville, GA 30504

(770) 531-3973 (phone)

emcgahee@hallcounty.org

<http://dph.georgia.gov/environmental-health> (State Website)

<http://www.phdistrict2.org/HallCounty.htm> (District Website)

<https://www.hallcounty.org/192/Environmental-Health> (County Website & Forms)

EMAIL Reader Advisory Notice: Email to and from a Georgia state agency is generally public record, except for content that is confidential under specific laws. Security by encryption is applied to all confidential information sent by email from the Georgia Department of Public Health (DPH). This message is only intended for specific recipient(s) and may contain privileged, private, or sensitive information. If you received this message in error, please delete it, and contact me.

Anael Dominguez (Planning)

From: Emily McGahee (Environmental Health)
Sent: Wednesday, June 15, 2022 2:44 PM
To: Randi Doveton (Planning); Anael Dominguez (Planning)
Cc: Chad Harper (Environmental Health); Kelly Hairston (Environmental Health)
Subject: HCPC Tentative Agenda 7.5.22

Please find Environmental Health comments below:

Item 1, 3053, 3087 McEver Road, Botrus: No parking of stock, employee, or customer vehicles on top of or within 5' of drainline or 10' from septic tank. Environmental Health will not approve any additional paved/gravel parking on parcel.

Item 2, 6286 Grand Fox Circle, Hewell: The proposed garage location was approved by Environmental Health on February 10, 2022.

Item 3, 5727/5769 Henson Road, Crawford: No comment.

Item 4, 2002 Memorial Park Drive, Sanchez: Must meet all Environmental Health commercial septic system permitting requirements. A detailed business plan must be submitted to Hall County Environmental Health for review. Additional items, including, but not limited to: recorded plat, soil evaluation, and septic system installation/modification may be required after review of business plan.

Item 5, 4745 Cagle Mill, Boling: Public sewer. Any abandoned well shall be properly closed as per Water Well Standards Act. Any abandoned septic tank shall be pumped by a State certified pumper/hauler and crushed/filled.

Item 6, 4740 Youngblood Road, Magnus: Connection to public sewer required.

Item 7, 4610/4616 Winder Hwy, Ponderosa Land Holdings: Public sewer. Any abandoned well shall be properly closed as per Water Well Standards Act. Any abandoned septic tank shall be pumped by a State certified pumper/hauler and crushed/filled.

Emily McGahee
Hall County Environmental Health
Hall County Government Center – 3rd Floor
2875 Browns Bridge Road
Mailing: PO Box 5901
Gainesville, GA 30504
(770) 531-3973
(770) 531-6767 (fax)

<http://dph.georgia.gov/environmental-health> (State Website)
<http://www.phdistrict2.org/HallCounty.htm> (District Website)
<http://www.hallcounty.org/devserv/environmental.asp> (County Website & Forms)