

## Kaitlyn Elliott (Planning)

---

**From:** Emily McGahee (Environmental Health)  
**Sent:** Monday, September 16, 2024 3:52 PM  
**To:** Kaitlyn Elliott (Planning); Beth Garmon (CDI: Planning); Katie L. Greenway (CDI: Planning)  
**Cc:** Chad Harper (Environmental Health); Kelly Hairston (Environmental Health)  
**Subject:** HCPC Tentative Agenda 10.21.24

Please find Environmental Health comments below:

Item 1, 6178 Grant Ford Road, Caswell: All proposed structures must meet all residential permitting requirements and/or required setbacks to existing septic system. An existing system evaluation/site visit will be required for Environmental Health to process the building permit application.

Item 2A/B, 5563 Waterwood Drive, Brumbelow: Environmental Health performed an existing system evaluation in regards to the proposed mobile home on August 15, 2024 and has no issues with the current 2 bdrm mobile home replacement location.

Item 3, 0/3902 Belmont Hwy, Simpson: No comment.

Item 4, 1780 Hancock Ave Ext, Jones Tree Service: Must meet all Environmental Health commercial septic system permitting requirements. Further determination will be made during the civil plan review process. A detailed business plan must be submitted to Hall County Environmental Health for review. Additional items, including, but not limited to: recorded plat, soil evaluation, and septic system installation/modification may be required after review of business plan.

Item 5, 6619 Lanier Island Pkwy, UHC: The existing onsite sewage management system is sized/approved for 5 employees only.

Item 6A/B, 2811 Athens Hwy, Dunagan: Must meet all Environmental Health commercial septic system permitting requirements. Further determination will be made during the civil plan review process. A detailed business plan must be submitted to Hall County Environmental Health for review. Additional items, including, but not limited to: recorded plat, soil evaluation, and septic system installation may be required after review of business plan.

Item 7, 0/2010 Candler Road, Dunagan: All proposed lots must meet Hall County Board of Health Lot Size Resolution requirements. Please note that Zoning approval does not imply approval from other county departments. Further determination will be made during the plat review process.

Item 8, 0/4435 Ridge Road, Puckett: Public sewer. A Food Service permit/plan review may be required depending on businesses proposed. Any abandoned well shall be properly closed as per Water Well Standards Act. Any abandoned septic tank shall be pumped by a State certified pumper/hauler and crushed/filled.

Item 9, 5859/5871 Brookton Lula Road, Helton: No comment.

Emily McGahee

Hall County Environmental Health

Hall County Government Center

2875 Browns Bridge Road

Mailing: PO Box 5901

Gainesville, GA 30504

(770) 531-3973 (phone)

[emcgahee@hallcounty.org](mailto:emcgahee@hallcounty.org)

<http://dph.georgia.gov/environmental-health> (State Website)

<http://www.phdistrict2.org/HallCounty.htm> (District Website)

<https://www.hallcounty.org/192/Environmental-Health> (County Website & Forms)

EMAIL Reader Advisory Notice: Email to and from a Georgia state agency is generally public record, except for content that is confidential under specific laws. Security by encryption is applied to all confidential information sent by email from the Georgia Department of Public Health (DPH). This message is only intended for specific recipient(s) and may contain privileged, private, or sensitive information. If you received this message in error, please delete it, and contact me.