

**Subject:** 5349 Browns Bridge Road Water Availability

**From:** Nick Swafford <NSwafford@gainesvillega.gov>

**Date:** 8/22/2024, 2:43 PM

**To:** "Kristie Turner (Planning)" <kturner@hallcounty.org>

**CC:** Rick Freeland <[REDACTED]>, Chris Thornhill <CThornhill@gainesvillega.gov>

Good afternoon Kristie,

Please allow this email to serve as confirmation of water availability for the subject property. The City owns and operates an existing 6" DIP water main on Browns Bridge Road and has sufficient domestic capacity to serve the proposed tire shop. Let me know if you need anything further.

Thanks,

**Nick Swafford**

**Permitting Services & GIS Manager**

**Department of Water Resources**



O | 770.538.2452

[www.gainesville.org](http://www.gainesville.org)

300 Henry Ward Way, Ste. 305  
Gainesville, GA 30501