



2978 Athens Highway Water Availability

From Kaitlyn Elliott (Planning) <kelliott@hallcounty.org>

Date Fri 4/25/2025 10:12 AM

To Kaitlyn Elliott (Planning) <kelliott@hallcounty.org>

From: Nick Swafford <NSwafford@gainesvillega.gov>

Sent: Friday, April 25, 2025 9:15:55 AM

To: Katie L. Greenway (CDI: Planning) <klgreenway@hallcounty.org>

Cc: rsfreeland@charter.net <rsfreeland@charter.net>

Subject: 2978 Athens Highway Water Availability

CAUTION: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Good morning Katie,

Please allow this email to serve as confirmation of water availability for the subject address. The City of Gainesville owns and operates an existing 8-inch DIP water main in the right-of-way of Athens Highway along the frontage of the subject property. The City currently has adequate domestic water capacity for the proposed convenience store.

Please let me know if you have any questions or need anything further.

Thanks,

Nick Swafford

Permitting Services & GIS Manager

Department of Water Resources



O | 770.538.2452

www.gainesville.org

300 Henry Ward Way, Ste. 305

Gainesville, GA 30501