

From: Nick Swafford <NSwafford@gainesvillega.gov>
Sent: Thursday, May 22, 2025 9:31 AM
To: Katie L. Greenway (CDI: Planning)
Cc: Tyler Lasser
Subject: 5979 New Bethany Water Availability

CAUTION: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Good morning Katie,

The City of Gainesville currently owns and operates an existing 6-inch water main in the R/W of Beards Road that currently terminates approximately 180' from the subject property. Service of public water by the City of Gainesville is currently not available. In order to connect to Gainesville's public water system, a developer-constructed water main extension would be required. Please let me know if you need anything further.

Thanks,

Nick Swafford
Permitting Services & GIS Manager
Department of Water Resources

O | 770.538.2452
www.gainesville.org

300 Henry Ward Way, Ste. 305
Gainesville, GA 30501