

---

## Fire Comments

---

From John Hornick (Fire Services) <jhornick@hallcounty.org>

Date Fri 1/23/2026 3:20 PM

To Katie G. Ahmed (Planning) <kahmed@hallcounty.org>

Cc Kaitlyn Elliott (Planning) <kelliott@hallcounty.org>

March 26, 2026, Hall County Board of Commissioners meeting

[5001 Bryant Quarter Road](#) | [Variance to Section 9.2.4](#) | [to reduce the required road frontage](#) | [on a proposed 4.96± acre tract located on the north side of Bryant Quarter Road approximately 1180 feet southwest of its intersection with Emory Griffin Road](#) | [Zoned AR-1; Tax Parcel 15003 000193 \(pt\)](#) | [Proposed Use: 4-lot subdivision](#) | [Commission District 3](#) | [Yajaira Rodriguez, applicant](#)

Hall County Fire Marshal Office Comments:

The fire apparatus access route from Bryant Quarter Road to the proposed 20 foot wide gravel drive extension is only 13 feet wide. Fire code requires the 13 foot wide fire access drive to be widened to 20 feet.

### **International Fire Code 2018 Edition, Section 503.2.1 Dimensions.**

Fire apparatus access roads shall have an unobstructed width of not less than 20 feet, exclusive of shoulders.

**The Hall County Fire Marshal's Office has no comments as proposed.**

Regards,

**John Hornick, NPQ Fire Service Plans Examiner 1**

Lieutenant, Hall County Fire Rescue

Hall County Government

Main: 770-531-6838 | Cell: 404-597-0083

Website: [www.Hallcounty.org](http://www.Hallcounty.org)

