



Customer Name : JANETH OCHOA

Assembly Location and Contact

Service Street Address	102 Near Way	Location of Assembly	front yard green box under bushes front of handicapped spot at meter	Contact Person Name	Janeth Ocha
Customer Email		Contact Cell Number			

Assembly Details

Meter Number		MXU Number	142793578	Type of Assembly	DC
Manufacturer	Watts	Model	007M3QT	Size	3/4"
Serial Number					

General Test Info

Test Date (Date Format XX/XX/XXXX)	07/03/2026	Test Time	11:30 AM	Line Pressure at Time of Test	100
------------------------------------	------------	-----------	----------	-------------------------------	-----

Check Valve No. 1 Initial Test

Closed Tight?	Yes	Check Valve 1 Reading	1.6
---------------	-----	-----------------------	-----

Check Valve No. 2 Initial Test

Closed Tight?	Yes	Check Valve 2 Reading	2.0
---------------	-----	-----------------------	-----

Remarks

Remarks (Enter Repair Comments Here)	061120-001 1193880608
--------------------------------------	-----------------------

Final Test

Status	PASSED
--------	--------

Test Kit Information

BFP Test Kit Model Number	845	Kit Manufacturer	Midwest	Kit Serial Number	07170303
Calibration Due Date (Date Format XX/XX/XXXX)	08/13/2026	Calibration Company	ABP Inc.		

Signoff

Tested By	Joshua Jones	Testing Company Name	Affordable Backflow Testing	Tester Cell Number	
Training Certificate Number	BPAT64787293	Certificate Expiration (Date Format XX/XX/XXXX)	07/30/2029	YOUR NEXT TEST DATE IS (Date Format XX/XX/XXXX)	07/03/2027